



MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE)
16, RAJ PUR ROAD, DELHI – 110054



DHO/CLZ/2025/1934

Dated: 11/12/25

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by public health inspector Civil Lines Zone from Public Health Department, inspected the M/S Jesus Grace Modern School (Sr. Sec.) situated at Street No.-13B, A-Block, Baba Colony, Burari Delhi- 110084 on 11.12.2025 and found that the school is running under sanitary and hygienic conditions from health point of view.

School has safe drinking water facilities for the students and members of staff of the institution and maintaining the hygiene and sanitation condition in the school building and the campus.

The above certificate is valid for 1 year from date of issue.

Manager

M/S Jesus Grace Modern School (Sr. Sec.)
at Street No.-13B, A-Block, Baba Colony,
Burari Delhi- 110084


Dy. Health Officer
Civil Lines Zone

Deputy Health Officer
Civil Lines Zone
Municipal Corporation of Delhi
16, Rajpur Road, Delhi- 110054



DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54



TEST REPORT

Sample ID	Ref. No. D.J.B/DTQC/Wzd./2025-26/188-189		
Location /Address of Sample	Jesus Grace Modern School (Sr.Sec.), Street No. 13B, Baba Colony, Burari, Delhi-110084		
Letter Reference No.	JGMS/336/01/2025	Ref. Letter Date	10.12.2025
Challan No.	223	Challan Date	10.12.2025
Sample Collection date	12.12.2025	Analysis start date	12.12.2025
Any other Information	--	Analysis end date	15.12.2025
		Reporting date	15.12.2025

TEST RESULTS

S.No	Parameters	Unit	As per the IS 10500		Inlet	Outlet (RO)
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	4.3	1.0
4	pH Value at 27 °C	--	6.5-8.5	No relaxation	7.54	7.14
5	Electrical Conductivity	µS/cm	-	-	763	129
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	496	84
7	Total Alkalinity as CaCO ₃	mg/L	200(Max)	600(Max)	152	20
8	Total Hardness as CaCO ₃	mg/L	200(Max)	600(Max)	268	32
9	Calcium as Ca	mg/L	75(Max)	200(Max)	66	7
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	25	3.4
11	Iron as Fe	mg/L	1.0(Max)	No relaxation	0.08	0.04
12	Chloride as Cl	mg/L	250(Max)	1000(Max)	116	20
13	Fluoride as F	mg/L	1.0(Max)	1.5(Max)	0.63	0.26
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate as NO ₃	mg/L	45(Max)	No relaxation	14.7	8.3
16	Sulphate as SO ₄	mg/L	200(Max)	400(Max)	55	9
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	BDL	BDL
18	Coliform Count 37°C (MPN)	/100 mL	Absent	No relaxation	0	0

*BDL=Below Detection Limit

.....End of Report.....

Remarks: Samples collected confirms specification for tested parameters and can be considered for the drinking purpose.

Tested by
Lab. Tech.

Verified for Chemical parameters
Asstt. Chemist

Verified for MPN
Asstt. Bact.

Authorized by
Chemist

ACWA(WZD)

Asstt. Chief Water Analyst
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad